

Ice Ice Baby - Predicting Freezing Rain and Wet Snow Icing Impacts

CoCoRaHS Webinar - Nov 11, 2021


Dr. Jay Shafer: jason.shafer@northernvermont.edu



Thank you for your service - CoCoRaHS Observers!



Extreme Weather and Power Outages: USA



EPRI: 2010

Three Icing Types

1. Rime



2. Wet Snow



3. Freezing Rain



Rime Icing

- Need to be in the cloud
- More likely at higher elevations
- Ice grows into the wind as cloud droplets freeze on contact
- Difficult to predict with conventional weather forecast approaches
- Key signatures: Higher water content clouds, high winds, 20-32°F)



Wet Snow Icing

- Partially melted snow crystals stick and/or refreeze to surfaces
- Difficult to forecast fraction of snow that sticks or accretes
- Problematic on trees in/near ROW
- Key signatures: higher water content, isothermal atmosphere, rain to snow transitions, temps remaining around $\sim 32^{\circ}\text{F}$)




Freezing Rain Icing

- Most studied icing
- Rain freezes on contact, after falling through subfreezing layer
- Efficiency of ice formation depends on:
 - Air temperature
 - Wind speed
 - Precipitation rate
 - Material characteristics




Thermal Structure and Precipitation Types



Long duration freezing rain is actually fairly rare - cold air needs replenishing at the surface, since latent heat is released warming the air when water freezes at the surface.

Newspaper Articles about Power Outages Call 2010



Key

- Article about power outages (and possibly other utilities)^{1,2}
- Article about telephone or cable, but not electrical, outages
- Storm-related articles, but none discussing utilities
- No articles about local impacts

Note: A gap between circles indicates that no edition was published.

Note 1: AP articles not included. Note 2: Articles outside the local area not included. Note 3: Weekly newspaper. Note 4: Based on the archives of Russ Murley, local meteorologist. Note 5: Based on newspapers included in "2000 ice storm archive" at Texas A & M University - Texarkana. Combined edition Dec 27-28.

Total Number of Glaze Icing Storms 1928 to 1937






FIG. 1. Total number of glaze storms, without regard to ice thickness, observed during the 8-year period of the Association of American Railroads Study (Bennett, 1959).


Mean annual 3 h periods of freezing rain 1980-2009




Average Number of Days with Freezing Rain (1948-2000)



The average annual number of days with freezing rain, based on 1948-2000 data. From Changnon and Karl, 2003.



National Electric Safety Code (NESC) - Ice Loading Zones (2002)



These codes are used in designing electric transmission structures.

Table 1: Loading Per District [1]

	Heavy	Medium	Light
Radial Thickness of ice (inch)	0.5	0.25	0
Horiz. Wind Pressure (lb/ft ²)	4	4	9
Temp.	0°F	15°F	30°F

50-Year Ice Storm - Ice Loading Map





Figure 3. 50-year return-period ice-load map from ASCE 74 (1991).

Ice growth on trees is complex




Icicles are more likely to form around freezing and warmer temperatures.

Figure 2: Glaze ice on tree branch cross-section (with surface below freezing) in freezing rain.


(after Makkonen 1998)

Koder 2016


100% freeze




90% freeze



wind effect



60% freeze



Winds act to distort ice growth

Winds generally spread ice around branches




Figure 11: Ice accumulation on branches with wind and no wind.

(same depth of freezing rain intercepted & uniform dry growth form ice)
(Jones 1996) (Yip 1995)

Koder 2016

Most commonly adopted method for converting freezing rain to ice thickness...

VOLUME 31

WEATHER AND FORECASTING

AUGUST 2016

Analysis of Ice-to-Liquid Ratios during Freezing Rain and the Development of an Ice Accumulation Model


KRISTOPHER J. SANDERS AND BRIAN L. BARJENBRUCH

NOAA/National Weather Service, Topeka, Kansas

FRAM - Freezing Rain Accumulation Model: Converts freezing rain to ice thickness values using three variables:

1. Wet bulb temperature
2. Precipitation rate
3. Wind speed

Ice Thickness vs. Radial Ice Thickness



There's a lot of confusion around understanding ice thickness. When most folks talk about ice thickness, they are referring to the maximum one-dimensional ice on an elevated surface. However, for engineering applications radial ice thickness is used for design standards around icing.

Measuring ice accretion is difficult

Ice Thickness – Largest one-dimensional ice growth aka “elevated flat ice”




Radial Ice – Average ice thickness distributed completely around a cylinder



Ice Thickness vs. Radial Ice Thickness




Example of one-dimensional ice thickness



Radial ice thickness distributes ice around a cylinder (wire), and is approximately 39% of value of one-dimensional ice thickness.

For example: 0.5" of radial ice = 1.27" of one-dimensional ice

January 5-10, 1998 Modeled Total Ice Thickness (inches)



January 5-10, 1998 Observed Total Ice Thickness (inches)

Table 4. Possible effect of elevation on ice load.

Station	Elevation range (ft)	Ice load (in.)
Burlington, VT	340-900	1.1
	900-	1.2
Barre, VT	1160-1720	0.2
	1720-	1.1
Hanover, NH	500-780	0.0
	780-1060	0.8
	1060-1340	0.9
	1340-	1.0
Concord, NH	340-900	0.1
	900-1460	0.5
	1460-	0.6
Portland, ME	100-660	0.5
	660-	0.9
Brunswick, ME	80-630	0.6
	630-	0.7
Augusta, ME	350-	0.8
Bangor	190-	1.2




Figure 20. Ice loads at weather stations in the United States and Canada in the January ice storm.
Jones and Mulherin 1998



a. Crescent on one side (photo Jones).



b. Large accretion on windward side of car antenna (photo Jones).



c. Icicles on wire fence (photo Mulherin).




d. Knobby accretion on Triplex (photo Mulherin).




Jones and Mulherin 1998

Figure 9. Examples of ice accretion shapes, January 1998 ice storm.


December 11 & 12, 2008 Total Ice Thickness



October 29-30, 2011 Wet Snow Icing Accretion



Method for Detecting Wet Snowfall Icing using Humidity and Temperature




Central Research Institute of Electric Power Industry - Sugimota et al. 2016

Wet snowfall risks are likely 3x to 4x the overall risks of outages than freezing rain in the Northeast US.

Wet Snow Forecast Example

Initialized: Sun 26 Apr 2020 at 00 UTC Valid: Tue 28 Apr 2020 at 00 UTC


Forecast Wet Snow



0 0.01 0.05 0.1 0.25 0.5 0.75 1 1.5 2
25th Percentile 48-HR Accumulated Wet S

Valid: Mon 27 Apr 2020 at 11 UTC

Observed Wet Snow



0.5 0.75 1 1.5 2 2.5 3 4 5 6 10
25th Percentile 48-HR Accumulated Wet Snow Liq. Eq (in)


Green Mountain Power 1 hr

Spring in VT! GMP line crews took this pic today in the Ludlow area where heavy wet snow is weighing down branches and making it look like winter. Stay safe!




Table used by Vermont CoCoRaHS observers to estimate ice accretion

Category	Ice Thickness (inches)	Description
0	zero	no ice or a trace
1	0.01-0.05"	enough to be annoying scraping off your car & look pretty on bushes, shrubs
2	0.06-0.10"	shrubs and other non-native shrubbery weighed down, trees manage ok
3	0.11-0.15"	small tree branches start to bend
4	0.16-0.20"	small and medium branches bend, a few small branches may fail
5	0.21-0.25"	birch trees are starting to bend, minor branch damage to weak trees
6	0.26-0.30"	birch trees sag moderately, small and large limbs start to break, ~5-10% branch loss
7	0.31-0.40"	birch trees bent nearly completely, ~10-20% branch loss on small and large limbs
8	0.40-0.50"	moderate to significant tree damage, most trees have some damage



Citizen Science - Ice Observations

Dec 23, 2017 Ice Thickness






National Weather Service - Current Limitations of Ice and Wet Snow Forecasts

- Lead time limited to 72 hours for ice
- Lacking probabilistic ice accretion forecasts
- No way to determine wet snow accretion from total snowfall
- No good products for precipitation that starts as freezing rain - “rapid onset freezing rain”

The first 0.01” of ice is the worst for transportation applications.




General risk scale for ice and concurrent wind loading




Sperry-Piltz Ice Accumulation Index (SPIA)	
ICE DAMAGE INDEX	DAMAGE AND IMPACT DESCRIPTIONS
0	Minimal risk of damage to exposed utility systems; no alerts or advisories needed for crews, few outages.
1	Some isolated or localized utility interruptions are possible, typically lasting only a few hours. Roads and bridges may become slick and hazardous.
2	Scattered utility interruptions expected, typically lasting 12 to 24 hours. Roads and travel conditions may be extremely hazardous due to ice accumulation.
3	Numerous utility interruptions with some damage to main feeder lines and equipment expected. Tree limb damage is excessive. Outages lasting 1 – 5 days.
4	Prolonged & widespread utility interruptions with extensive damage to main distribution feeder lines & some high voltage transmission lines/structures. Outages lasting 5 – 10 days.
5	Catastrophic damage to entire exposed utility systems, including both distribution and transmission networks. Outages could last several weeks in some areas. Shelters needed.

Figure 18: Determining SPIA Index severity categories using ice accumulation (inches) and wind speed (mph).
(derived from NOAA 2009)

Probability of 0.5" of Elevated Ice Thickness




Example private-sector ice accretion forecast



Conducting Research on Ice - Hubbard Brook, NH



Wet snow and ice risks and climate change





Dr. Jason Shafer
Northern Vermont University
jason.shafer@northernvermont.edu



First responder to the future.